

Fume cabinet & LEV locations within the University of Lincoln – 21st January 2016 – revision 19

Building	Serial Number/ Asset number	Room number And/or name	Floor/ contact	2016 Face velocity	2015 face velocity	2014 face velocity	2013 face velocity	Log book number	comments
BR007	030592*	Generic lab 3 SB009	Ground CC		0.52 m/s	0.57 m/s	0.57m/s	Book 1	SB = Science building BR007
BR007	030593*	Generic lab 3 SB009	Ground CC		0.51 m/s	0.50 m/s	0.51 m/s	Book 2	
BR007	030594*	Research lab 3 SB010	Ground CC		0.45 m/s	0.50 m/s	0.60 m/s	Book 3	Retested after new fan fitted
BR007	030595*	Research lab 3 SB010	Ground CC		0.54 m/s	0.52 m/s	0.59m/s	Book 4	Retested after new fan fitted
BR007	030596*	Biomed teaching lab SB012	Ground CC		0.57 m/s	0.63 m/s	0.62m/s	Book 6	Retested after new fan fitted
BR007	030597*	Biomed teaching lab SB012	Ground CC		0.52 m/s	0.58 m/s	0.59m/s	Book 7	Retested after new fan fitted
BR007	4835*	Prep room SB013	Ground CC		0.42 m/s	n/a	n/a		
BR007	FC1*	Generic lab SB109	First CC		0.53 m/s	0.52 m/s	0.53m/s	Book 15	
BR007	FC2*	Generic lab SB109	First CC		0.63 m/s	?	0.62m/s	Book 16	Broken front 15/10/15
BR007	FC3*	Generic lab SB109	First CC		0.54 m/s	0.51 m/s	0.53m/s	Book 17	
BR007	200270*	Pharmacy formulation lab SB105	First CC			?	0.73m/s	Book 14	
BR007	200265*	Generic lab 1 SB108	First CC		0.61 m/s	0.70 m/s	0.71m/s	Book 12	
BR007	200259*	Generic lab 1 SB108	First CC		0.69 m/s	0.69 m/s	0.69m/s	Book 8	
BR007	200267*	Generic lab 1 SB108	First CC		0.55 m/s	0.56 m/s	0.60m/s	Book 13	
BR007	200262*	Generic lab 1 SB108	First CC		0.70 m/s	0.62 m/s	0.62m/s	Book 9	
BR007	200264*	Generic lab 1 SB108	First CC		0.58 m/s	0.55 m/s	0.55m/s	Book 11	